

STRATEGIC BUSINESS PLAN (SBP)

IEC/COMMITTEE:	SECRETARIAT:	DATE:
115	China	2022-12

Please ensure this form is annexed to the Report to the Standardization Management Board if it has been prepared during a meeting or sent to the IEC Secretariat promptly after its contents have been agreed by the committee.

A. STATE TITLE AND SCOPE OF COMMITTEE

Are there any new or emerging trends in technology that will impact the scope and work activities of the committee? Please describe briefly.

Do you need to update your scope to reflect new and emerging technologies? If yes, will these changes impact another committee's scope or work activities?

If yes, describe how these will impact another committee(s) and list the committee(s) it would impact

Title: High Voltage Direct Current (HVDC) Transmission for DC Voltages Above 100 kV

TC 115 was established in August 2008 to meet the requirements concerning rapidly emerging HVDC system market. HVDC transmission offers for power systems important benefits of flexibility, controllability, cost-effectiveness and environmentally-friendliness. It presents significant advantages for large-capacity power transmission over long distances as well as for the interconnection of power systems. Since the first commissioned HVDC project in 1950s, more than 100 HVDC projects have been put into service, among which over 80% were planned and built after 1980. In view of the wide use of HVDC, the improvement of the existing and creation of new standards for the HVDC transmission will be important in the areas of planning, design, construction, operation and maintenance of HVDC system as well as in the areas of design, manufacturing, and testing of the HVDC transmission equipment.

Scope of TC 115:

Standardization in the field of HVDC Transmission technology above 100 kV. The task includes HVDC system-oriented standards as design aspects, technical requirements, construction and commissioning, reliability and availability, and operation and maintenance. Standards of HVDC equipment so far related to the system aspects will be prepared in close collaboration and in joint responsibility with the relevant Technical Committees and Subcommittees.

The objective of TC 115 is to establish a standard system for HVDC transmission as well as to promote new standards within TC 115's scope.

Road map on Standardization of HVDC technology

TC 115 has established an Advisory Group to prepare the road map and review the document regularly to make it suitable for the need of technology development and market. It also functions as an editing committee for new documents before circulating them for voting, and also includes coordination of HVDC grids. Membership consists of TC 115 officers, one representative from each P-member country and others by invitation.

B. MANAGEMENT STRUCTURE OF THE COMMITTEE

Describe the management structure of the committee (use of an organizational chart is acceptable) (should be integrated by IEC Secretariat automatically) and, if relevant (for example an unusual structure is used), provide the rationale as to why this structure is used.

Note: Check if the information on the IEC website is complete.

When was the last time the committee reviewed its management structure? Describe any changes made. When does the committee intend to review its current management structure? In the future, will the committee change the current structure, for example due to new and emerging technologies, product withdrawal, change in regulations etc. Please describe.

Make sure the overview includes:

- any joint working groups with other committees,
- any special groups like advisory groups, editing groups, etc.

Secretariat: China

Officers:

Chair: Mr. Marcus Häusler (DE)

Secretary: Mr Jun YU (CN)

Assistant Secretary: Ms Chen GU (CN)

Technical officer: Ms Suzanne Yap Geok Sim

Advisory Group, Working Groups and Maintenance Teams:

AG 1: Road map on standardization of HVDC technology and editing committee

WG 2: Reliability and availability evaluation of HVDC systems

WG 3: Electromagnetic performance of high-voltage direct current (HVDC) overhead transmission lines

WG 4: Guidelines on Asset Management for HVDC Installations

WG 5: Guideline for the System Design of HVDC Converter Station with Line-commutated Converters (LCC)

WG 6: Guidelines for operation and maintenance of line commutated converter (LCC) HVDC converter station

WG 7: DC side harmonics and filtering in HVDC transmission systems

MT 8: Design of earth electrode stations for high-voltage direct current (HVDC) links - General guidelines

WG 9: High voltage direct current (HVDC) power transmission- System requirements for DC-side equipment

WG 10: Guideline for planning of HVDC systems - Part 1: HVDC systems with line commutated converters

JWG 22: Atmospheric and altitude correction (managed by TC 42)

JMT 1: High voltage direct current (HVDC) substation audible noise (linked to SC 22F)

JMT 5: Maintenance Team for IEC 60919 series, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters* (managed by SC 22F)

JMT 7: Revision of IEC/TS 61936-2 *Power installations exceeding 1 kV a.c. and 1,5 kV d.c. - Part 2: d.c.* (managed by TC 99)

JWG 11: Performance of voltage sourced converter based high-voltage direct current transmission (linked to SC 22F)

WG 12: Life extension guidelines for HVDC converter stations

WG 13: Testing and commissioning of VSC HVDC schemes

JWG 14: DC voltages for HVDC grids

WG 15: System Aspects of HVDC Grids

WG 16: Guidelines for parameters measurement of HVDC transmission line

JWG 13: Insulation co-ordination for HVDC systems (managed by TC 99)

JWG 38: Control and protection systems for high-voltage direct current (HVDC) power transmission systems - Functional performance tests (PWI 22F-15) (managed by SC 22F)

Review of Management Structure

The Management Structure was last reviewed during the plenary meeting via Zoom on 2022-11-15/16.

The Management Structure will next be reviewed during plenary meeting.

C. BUSINESS ENVIRONMENT

Provide the rationale for the market relevance of the future standards being produced in the committee.

If readily available, provide an indication of global or regional sales of products or services related to the committee work and state the source of the data.

Specify if standards will be significantly effective for assessing regulatory compliance.

HVDC power transmission technology is one of the most important application of power electronics in electrical transmission and distribution systems resulted from the tremendous progress in the development of power semi-conductor devices and conversion technique during the last 60 years. With great technical advantages (integration into the interconnected grids, interconnection of grids with asynchronous power systems, bulk power transmission over long distance, submarine cable power transmission etc.), HVDC transmission has been widely used in the world.

D. MARKET DEMAND

Provide a list of likely customers of the standards (suppliers, specifiers, testing bodies, regulators, installers, other committee's etc.). Do not specify company names, only categories of customers.

With the increase of voltage level and transmission distance of HVDC transmission projects, apart from domestic extensive construction, cross-border interconnection of energy export and import countries through HVDC transmission projects are emerging. Since the construction of HVDC transmission projects is capital-intensive while the number of these projects having been built is limited, and the establishment of standards with respect to the HVDC transmission technologies has to include different design, construction and operation experience, it would be difficult to set up these standards by a single country or based on one single HVDC project. The standards to be developed by TC 115 for HVDC transmission will therefore incorporate experience gained by numerous experts all around the world who have been involved in construction and operation of HVDC projects. As a result, such standards would attract wide attention and be applied by engineers participating in design, construction, operation and maintenance of HVDC transmission projects, as well as those engaged in studies for HVDC transmission technologies in different countries and areas. Besides, individual HVDC transmission equipment manufacturers will also employ relevant standards and equipment technical criteria established by TC 115 and other TCs to guide design, manufacturing, and testing of equipment.

The users of the outputs of TC115 are asset owners, operators, regulators, purchasers, suppliers, specifiers, testing bodies, and other TC/SCs.

E. SUSTAINABLE DEVELOPMENT GOALS

Indicate the Sustainable Development Goals (SDGs) that are addressed by work within the committee. Indicate each SDG Indicator affected (reference spreadsheet available at <https://www.iec.ch/SDG/>, and provide specific information about how the committee is addressing the SDG. Consider both direct and indirect impacts of the work of the committee.

- | | |
|--|---|
| ☐ GOAL 1: No Poverty | ☐ GOAL 10: Reduced Inequality |
| ☐ GOAL 2: Zero Hunger | ☐ GOAL 11: Sustainable Cities and Communities |
| ☐ GOAL 3: Good Health and Well-being | ☐ GOAL 12: Responsible Consumption & Production |
| ☐ GOAL 4: Quality Education | ☐ GOAL 13: Climate Action |
| ☐ GOAL 5: Gender Equality | ☐ GOAL 14: Life Below Water |
| ☐ GOAL 6: Clean Water and Sanitation | ☐ GOAL 15: Life on Land |
| ☒ GOAL 7: Affordable and Clean Energy | ☐ GOAL 16: Peace, Justice Strong Institutions |
| ☐ GOAL 8: Decent Work & Economic Growth | ☐ GOAL 17: Partnerships to achieve the Goals |
| ☒ GOAL 9: Industry, Innovation & Infrastructure | |

As an effective way to solve the imbalance between energy demand and supply, HVDC technology has been widely used all over the world. The energy supply include power plants which are far away from load centres, and clean and renewable distributed generation. IEC TC 115 focus on the standard development on HVDC system aspects such as design, technical requirements, construction and commissioning, reliability and availability, operation and maintenance, and the system aspects of HVDC equipment which have an important impact on the security and stability of energy supply. With the development of HVDC transmission technology, the R&D and manufacturing technology of key equipment has been greatly improved, and it has promoted the progress of related industries.

F. TRENDS IN TECHNOLOGY AND IN THE MARKET

If any, indicate the current or expected trends in the technology or in the market covered by the products of your committee.

Trends in technology

With the growth of load demand and the imbalance between energy demand and supply, power plants are needed which are far away from load centres (e.g. large hydropower and pit-mouth fossil-fired power stations), and clean and renewable distributed generation (e.g. wind power and solar power) will be introduced to a great extent. The former are characterized by bulk power and long distance and will enjoy remarkable advantages when employing HVDC transmission technology. The latter are characterized by small capacity and dispersion leading to technical and economic disadvantages when employing conventional AC technology to interconnect them to the main power system. Therefore, adopting the new type voltage sourced converters based HVDC is a reasonable alternative. Consequently, the development of HVDC transmission technology is mainly oriented to:

- I. High voltage, high current and long-distance bulk power transmission. Currently, construction of HVDC transmission projects is characterized by:
 - High voltage: at present ± 1100 kV HVDC projects have been put into operation;
 - Bulk power transmission capacity; one bipole transmission capacity of (3 – 8) GW at present and up to 12 GW in the future;
 - Long transmission distance; the transmission distance has been increased to be more than 2500 km and will be potentially increased up to and even more than 3000 km.
 - Construction of HVDC transmission systems in severe environmental conditions, such as building converter station and DC transmission lines at very high altitude(3000m-5300m), posing higher requirements for the HVDC transmission technology.

All these features, however, also pose new challenges for HVDC transmission technology in the following aspects:

1. Increasing manufacturing challenges. For example, the design and manufacturing of ± 800 kV and above HVDC transmission equipment, e.g., converter transformer,

converter transformer bushing, wall bushing, converter valve and DC yard equipments etc. are becoming more challenging.

2. More stringent requirement in respect of equipment external insulation. With increased voltage level, the equipment external insulation is a concern. The HVDC transmission has imposed more stringent requirements on insulation of the line insulators. As a result, special provisions have to be made for external insulation of switchyards in converter stations.
3. Complex basic structure of main circuit in the converter stations. Converter valves in some of the ± 800 kV, ± 1100 kV HVDC transmission projects employ serial-connected (or parallel-connected) double 12-pulse valves, resulting in complex operating modes, higher control & protection reliability requirement as well as difficult equipment arrangement.
4. Higher requirement for environment-friendliness. The environmental concerns mainly include audible noise, radio interference and ground field strength, etc.
5. Higher electrode earth current. As an example, in case of monopole operation of HVDC transmission, the electrode current is as high as 5000 A or more, which poses challenges to consider and mitigate the risk of adverse effects on surrounding environment.
6. High impact on power system caused by pole blocking faults, and especially in case of bipolar faults.
7. New cable technology. High power transfer capacity requirement coupled with long distance HVDC submarine cable necessitates the use of new cable technology. The long submarine cable length hinders the use of conventional oil filled cable because of the difficulty in maintaining fluid pressure and since the cable cooling requirement such as oversized pumping station would make the project unfeasible. New development in the use of DC XLPE cable and MI-PPL (Mass Impregnated Polypropylene Layer) with cable insulation material at higher operating temperature may support the way to break current limits for HVDC submarine cable.

II. The VSC-HVDC technology has been widely used in integration and transmission of wind farms, interconnection with regional power grid, power supply for megacity center and other aspects. The market demand, in turn, promotes the technology development. Consequently, the development of VSC-HVDC transmission technology is mainly oriented to: bulk power and high voltage technology, multi-terminal HVDC technologies and overhead line VSC transmission and etc..

- High voltage and bulk power transmission.
- Multi-terminal HVDC(MTDC) transmission.
- Overhead line VSC transmission.

The trend in technology development described above makes desirable that TC 115 makes recommendations to relevant IEC TCs/SCs to update the existing standards, and alternatively, to establish new standards and technical reports which are not covered by the scopes of existing TCs/SCs. To cater the emerging new situations standards in the following areas are required to be established:

- Technical report for system design of VSC HVDC project.
- Technical reports of application guide for the various kind of equipment exclusively used in HVDC system.
- HVDC transmission system commissioning guideline for VSC scheme.
- HVDC transmission system operating and maintenance guidelines for VSC scheme.

- Standard/guideline for insulation coordination including altitude correction for HVDC system in high altitude areas.
- Standards/guidelines for VSC-HVDC transmission technologies.

Trends in the Market

In recent years, the amount of power transmission using HVDC technology has been significantly increased in both two major fields of their application: long-distance power transmission and interconnection of power systems.

HVDC can transmit more power per mono-polar over-head transmission line compared with HVAC single circuit. As economic and environmental aspects become more and more important, this boosts the HVDC applications. New dimensions of power transmission capabilities are reached with the development of HVDC technology at 800 kV and above as of 6-inch thyristors increasing the dc current capability above 5 kA.

The HVDC voltage range provides also a means for extra long-distance transmission schemes above 3000 km. Due to reduced losses, projects under consideration since several years such as feeding solar energy from Sahara desert to Europe are becoming more attractive economically.

Furthermore, DC technical advantages improve the extension of the existing ac power systems. A number of interconnections from mainland to islands and long undersea applications have been realized.

The development of voltage sourced converters (VSC) for HVDC applications provides technical features allowing connecting to weak AC system or to support the emerging of start-up system using the black-start capability. Presently, a number of voltage sourced converters based HVDC transmission projects are under construction and planned in Europe, North America, South America and East Asia. Connections of small electrical networks to the main grid become feasible.

Furthermore, detailed investigations have started evaluating benefits of connecting several DC links together forming multi-terminal HVDC grids.

G. SYSTEMS APPROACH ASPECTS (SEE DIRECTIVES PART 1 ANNEX SP)

Does your committee have a need for a systems approach?

If so:

- Will the Systems work be in a single committee or in multiple committees?
- Will a Standardization Evaluation Group (SEG), Systems Committee (SyC), or Systems Resource Group be required?
- Is your committee work of relevance to ISO?
- Is or are there fora or consortia working in parallel to IEC? Is there a chance to integrate this work in your committee?

This should not only be restricted to the customer/supplier relationships with other committees indicating types of co-operation (e.g. liaisons, joint working groups) but be of a more generic nature.

TC 115 will actively work side by side with the relevant IEC technical committees and sub-committees. This is crucial to perfect the system structure of TC 115 and ensure smooth progress of TC 115 activities. The following principles will be followed in the cooperation between TC 115 and other TC/SCs:

- I. TC 115 will submit its findings on relevant technologies, information as well as standards to other TC/SCs;
- II. TC 115 will accept all valuable information, standards as well as working experiences from other TC/SCs actively;
- III. TC 115 will cooperate with other TCs/SCs to establish HVDC related standards through:

- Sharing of information;
- Assignment of experts to participate in the meetings convened by the related committees and inviting the experts and management personnel from such committees to participate in the meetings convened by TC 115;
- Establishment of joint working groups.

TC 115 has already established liaison with TC17, SC 17A, SC 17C, SC 22F, TC 36, SC 36A, TC 38, TC 42, TC 99, TC 8, SC 8A, CIGRE SC B4, ISO/TC 251, and will establish liaison with TC 11, TC 14, TC 33, TC 37, TC 95. Additionally, TC 115 will cooperate with ISO, IEEE and CIGRE working groups.

H. CONFORMITY ASSESSMENT

With reference to Clause 33 of Part 2 of the ISO/IEC Directives, are all your publications in line with the requirements related to conformity assessment aspects?

Will the committee publications be used for IEC Conformity Assessment Systems (IECEE, IECEX, IECQ, IECRE)?

Will any of your standards include test specifications, reproducible test requirements, and test methods?

Are there likely to be special conformity assessment requirements generated by any standards projects? If yes, list which projects.

All publications of TC 115 are in line with the requirements related to conformity assessment aspects.

TC 115 publications are not used for IEC Conformity Assessment Systems (IECEE, IECEX, IECQ, IECRE) until now.

The following TC 115 publications include test specifications, reproducible test requirements, and test methods:

IEC TS 61973: High voltage direct current (HVDC) substation audible noise

IEC TS 62344: Design of earth electrode stations for high-voltage direct current (HVDC) links - General guidelines

IEC TS 63014-1: High voltage direct current (HVDC) power transmission - System requirements for DC-side equipment - Part 1: Using line-commutated converters

I. 3-5 YEAR PROJECTED STRATEGIC OBJECTIVES, ACTIONS, TARGET DATES

STRATEGIC OBJECTIVES 3-5 YEARS	ACTIONS TO SUPPORT THE STRATEGIC OBJECTIVES	TARGET DATE(S) TO COMPLETE THE ACTIONS
1. Establish cooperative relationship with the relevant TC/SCs of IEC. Subsequently, TC 115 will take initiatives in cooperating with TC 8, TC 14, SC 22F and TC 42 etc. and CIGRE etc.	Establish liaisons with following TCs and SCs: TC 11 and TC 14 in due time.	In due time
2. Based on evolution of the HVDC transmission technologies, to establish new	a) Circulate a NP of TS for WG 4 for TS on guidelines on asset management for HVDC	2023

standards that can reflect the state-of-the-art technical trends so as to satisfy the requirements in respect of planning, design, construction, operation and maintenance of HVDC transmission projects and other demands of users. During establishment of new standards and based on the actual situations of HVDC transmission technologies, relevant working groups will be set up on an as needed basis, and improve popularity of TC 115	installations.	
	b) Cooperate with TC 42 to accelerate the work of JWG 22 to develop the new work item proposal concerning external insulation correction for HVDC transmission system in high altitude area.	ongoing
	c) Start the maintenance work of WG 5 work for TR on Guideline for the System Design of HVDC Converter Station with Line-commutated Converters (LCC).	2023.
	d) Finish the maintenance work of WG 6 for TR on guidelines for the operation and maintenance of HVDC converter station.	Done.
	e) Continue the work of WG 10 to do maintenance on Planning of HVDC systems.	Ongoing.
	f) Continue the work of WG 9 to do maintenance on System requirements for testing DC side equipment Part I and start the work of Part II: VSC.	Ongoing.
	g) Continue the work of JWG11 on Performance of voltage sourced converter based high-voltage direct current transmission.	Work of Part 1 has been published and Part 2 has been started.
	h) Develop a new work item proposal according to the HVDC roadmap developed by TC 115 AG 1 on Guideline for the system design of VSC-HVDC	In due time.
	i) Establish a JWG with SC 22F according to the HVDC roadmap on technical report for Valve Cooling System Adopted in HVDC Converter Station	In due time.

	j) Continue the work of WG 12 on "Life extension guidelines for HVDC converter stations".	Ongoing.
	k) Continue the work of WG13 on "Testing and commissioning of VSC HVDC schemes".	Ongoing.
	l) Continue the work of WG15 on "HVDC Grid Systems and connected Converter Stations - Guideline and Parameter Lists for Functional Specifications - Part 1: Guidelines and Part 2: Parameter Lists".	Ongoing.
	m) Continue the work of JWG14 on "DC voltages for HVDC grids"	Ongoing.
	n) Circulate a NP of TS for WG 7 for TS on DC side harmonics & filtering in LCC HVDC transmission systems.	2023
3. Gain an insight into the current situation of technical publication adopted in the existing standards and work out the modified scheme based on the actual conditions of the projects as well as technical development status and actively cooperate with the relevant TC/SCs to complete revision of the existing standards and technical report	a) Start the maintenance of IEC/TS 61973 High voltage direct current (HVDC) substation audible noise	2023.
	b) Finish the review and maintenance of IEC/TS 62344 Design of earth electrode stations for high-voltage direct current (HVDC) links - General guidelines	Done.
	c) Finish the review and maintenance of IEC/TR 62672 Reliability and availability evaluation of HVDC systems	Done.
	d) Finish the review and maintenance of IEC/TR 62681 Electromagnetic performance of high voltage direct current (HVDC) overhead transmission lines	Done.

	e) Continue the work of TC99 JMT7 on maintenance of IEC/TS 61936-2, Power installations exceeding 1 kV a.c. and 1,5 kV d.c. - Part 2: d.c.	Ongoing.
	f) SC 22F JMT5 work on IEC TR 60919 series "Performance of high-voltage direct current (HVDC) systems with line-commutated converters"	Part I, Part 2 and Part 3 have been published.
4. Thorough and extensive investigation and research on the existing technical status of HVDC transmission projects and the requirements in respect of standards and technical specification imposed by the relevant projects at stages of planning, design, construction, operation and maintenance, the standards system in the HVDC power transmission will be established or refined	Update the Road Map on Standardization of HVDC Technology.	Annually.
Note: The progress on the actions should be reported in the RSMB.		